



**CITY OF NEW BRUNSWICK  
MINOR SITE PLAN COMMITTEE  
25 KIRKPATRICK STREET  
DEPARTMENT OF PLANNING, COMMUNITY  
& ECONOMIC DEVELOPMENT  
9:00 AM  
AUGUST 19, 2020**

**Call-In Phone Number**

**+1-408-418-9388**

**Access Code**

**710 200 298**

**WebEx Meeting URL**

**<https://newbrunswickpolicedepartment.webex.com/newbrunswickpolicedepartment/j.php?MTID=m3219d6c76ece32d3e4f2d683e73c5bf5>**

**Meeting Number**

**710 200 298**

**Meeting Password**

**NewBrunswick**

**MIDDLESEX WATER COMPANY / 7 JOHNSON DRIVE / BLOCK 95, LOT 7 (PB-2020-07)**

Minor site plan application to demolish an existing walk-in enclosure (measuring 20 feet by 10 feet) on the property in order to construct a new noise reducing walk-in enclosure (to measure 37 feet by 14 feet and 13.5 feet high) to house a new diesel standby generator, which is part of the existing raw water pumping station on the property. Other site improvements include the removal of an existing 4,000 gallon underground storage tank, removal of an existing transformer and concrete walkway, replacement of electrical ductwork, replacement of perimeter security fencing, and a new permeable pavement driveway area.